

Technical drawing of a concrete structure, likely a manhole or inspection chamber, showing dimensions and elevations.

Dimensions:

- Overall width: 3440
- Overall height: 3790
- Internal width: 2500
- Internal height: 2500
- Top flange thickness: 200
- Bottom flange thickness: 150
- Side wall thickness: 150
- Base thickness: 100
- Offset from wall to centerline: 460
- Offset from base to centerline: 860
- Offset from side wall to centerline: 2500
- Offset from base to centerline: 940
- Offset from top flange to centerline: 387,90
- Offset from side wall to centerline: 150
- Offset from base to centerline: 150
- Offset from top flange to centerline: 200
- Offset from side wall to centerline: 150
- Offset from base to centerline: 150

Elevations:

- Top flange top surface: 387,90
- Internal top surface: 386,50
- Internal bottom surface: 385,40
- Base bottom surface: 384,46
- Base bottom surface (right side): 384,11

Labels:

- SBĚRAČ "A" DN300 (Collection "A" DN300)
- VÝTLAČNÉ POTRUBÍ De110 (Discharge pipe De110)
- LITINOVÝ POKLOP 1000 x 1000 (Cast iron cover 1000 x 1000)

Notes:

- SBĚRAČ "A" (Collection "A")
- VÝTLAČNÉ POTRUBÍ De110 (Discharge pipe De110)
- LITINOVÝ POKLOP 1000 x 1000 (Cast iron cover 1000 x 1000)

PŮDORYSNÝ ŘEZ

SBĚRAČ "A" DN300

107°

1000

1000

1

1'

Ø2300

Ø2300

LEGENDA :

PREFE

BETON C30/37-XC4-CI 1,0

VÝTLAČNÉ POTRUBÍ De110

	PREFA
	BETON C30/37-XC4-Cl 1,0
	ŠTERKOPISEK

HLAVNÍ INŽENÝR PROJEKTU : ING. DANIEL KOTAŠKA			 PÍŠTOVY 680 TEL. 469 686 3 537 01 CHRUDIM FAX: 469 686 3 E-MAIL: EKOMONITOR@EKOMONITOR.CZ	
ZODPOVĚDNÝ PROJEKTANT	VYPRACOVAL :	TECHNICKÁ KONTROLA :		
PROFESE : V+K				
ING. DANIEL KOTAŠKA	JAROSLAVA ČMELÍKOVÁ	ING. DANIEL KOTAŠKA		
INVESTOR : OBEC RUDNÍK, RUDNÍK 51, 543 72 RUDNÍK			ČÍSLO ZAKÁZKY	X
NÁZEV AKCE : KANALIZACE – II. ETAPA RUDNÍK – TEREZÍN – POŠTA			FORMÁT A4	6
OBJEKT : SO 01 – KANALIZACE ČÁST : D – DOKUMENTACE OBJEKTŮ A TECHNICKÝCH A TECHNOLOGICKÝCH ZAŘÍZENÍ			DRUH PROJEKTU	DSP
			DATUM	06. 2016
			MĚŘÍTKO	1 : 50
NÁZEV VÝKRESU : ČERPAČÍ STANICE "Ad" – STAVEBNÍ VÝKRES			ČÍSLO VÝKRESU : D.6.2	PARÉ Č.: